



## Kiwa UK Regulation 4 (KUKreg4) Approval (ATS3)

Certificate number 2006752  
Date issued 18th June 2020  
Date expired 17th June 2025 Original/Amendment *Original*

**Description:** Range of flow sensors, having EPDM o rings and either brass, plastic or stainless steel bodies.  
Maximum working pressure 10 bar for models VVX15, VVX20, VVX25. 16 bar for models VVX32 & VVX40. Maximum operating temperature 90°C.

**UK Approval**  
Issued by Kiwa Watertec

**Product Designation:** VVX15, VVX20, VVX25, VVX32, VVX40

This is to certify that the above range of products manufactured/supplied by

**Company name: SIKA Systemtechnik GmbH**

Has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2014, Scotland and the Water Regulations, Northern Ireland.

This certificate must be read in conjunction with the acceptance letter for this product.

This approval is intended for compliance with the above Regulations and must not be considered equivalent to the product certification provided by Kiwa N.V.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements (IRNs) can be obtained from the acceptance letter supplied with this certificate.

Applicable IRNs for this certificate: R001

David Jay, Business Unit Manager – Authorised Signatory

Kiwa Watertec

**Certificate issued to:**  
SIKA Systemtechnik GmbH  
Struthweg 7-9  
34260 Kaufungem  
Germany

CERTIFICATE

3901770301

**Kiwa Watertec**  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
F +44 (0)495 304496  
uk.water@kiwa.com  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

